

| Model(s): EDLA06E23V3 / EKHWSU180D3V3 | | | |
|---|---------------|-------------|--------------|
| Air-to-water heat pump: Yes | | | |
| Water-to-water heat pump: No | | | |
| Brine-to-water heat pump: No | | | |
| Low-temperature heat pump: No | | | |
| Equipped with a supplementary heater: Yes | | | |
| Heat pump combination heater: No | | | |
| Parameters shall be declared for medium-temperature application, except for low-temperature heat pumps. For low-temperature heat pumps, parameters shall be declared for low-temperature application. | | | |
| Parameters shall be declared for average, colder and warmer climate conditions. | | | |
| Item | Symbol | Value | Unit |
| Rated heat output ⁽³⁾ | <i>Prated</i> | 7.0 | kW |
| Declared capacity for heating for part load at indoor temperature 20 °C and outdoor temperature T_j | | | |
| $T_j = -7\text{ °C}$ | <i>Pdh</i> | 5.9 | kW |
| $T_j = +2\text{ °C}$ | <i>Pdh</i> | 3.9 | kW |
| $T_j = +7\text{ °C}$ | <i>Pdh</i> | 3.0 | kW |
| $T_j = +12\text{ °C}$ | <i>Pdh</i> | 3.3 | kW |
| T_j = bivalent temperature | <i>Pdh</i> | 6.1 | kW |
| T_j = operation limit temperature | <i>Pdh</i> | 5.36 | kW |
| For air-to-air heat pumps: $T_j = -15\text{ °C}$ (if $TOL < -20\text{ °C}$) | <i>Pdh</i> | | kW |
| Bivalent temperature | T_{biv} | -6 | °C |
| Cycling interval capacity for heating | <i>Pcych</i> | | kW |
| Degradation co-efficient ⁽⁴⁾ | <i>Cdh</i> | | — |
| Power consumption in modes other than active mode | | | |
| Off mode | P_{OFF} | 0.010 | kW |
| Thermostat-off mode | P_{TO} | 0.010 | kW |
| Standby mode | P_{SB} | 0.010 | kW |
| Crankcase heater mode | P_{CK} | 0.000 | kW |
| Other items | | | |
| Capacity control | | | |
| Sound power level, indoor/outdoor | L_{WA} | / 60.0 | dB |
| Annual energy consumption | Q_{HE} | 4.441 16 | kWh or GJ |
| For heat pump combination heater: | | | |
| Declared load profile | L | | |
| Daily electricity consumption | Q_{elec} | 4.390 | kWh |
| Annual electricity consumption | <i>AEC</i> | 928 | kWh |
| Daikin Industries Czech Republic s.r.o. U Nove Hospody 1/1155, 301 00 | | | |
| Daikin Europe N.V. | | | |

| Item | Symbol | Value | Unit |
|---|-------------------------|---------------|--------|
| Seasonal space heating energy efficiency | η_s | 127 | % |
| Declared coefficient of performance or primary energy ratio for part load at indoor temperature 20 °C and outdoor temperature T_j | | | |
| $T_j = -7\text{ °C}$ | <i>COPd or PERd</i> | 1.98 79.2 | – or % |
| $T_j = +2\text{ °C}$ | <i>COPd or PERd</i> | 3.16 126.4 | – or % |
| $T_j = +7\text{ °C}$ | <i>COPd or PERd</i> | 4.49 179.6 | – or % |
| $T_j = +12\text{ °C}$ | <i>COPd or PERd</i> | 6.10 244.0 | – or % |
| T_j = bivalent temperature | <i>COPd or PERd</i> | 2.12 84.8 | – or % |
| T_j = operation limit temperature | <i>COPd or PERd</i> | 1.53 61.2 | – or % |
| For air-to-air heat pumps: $T_j = -15\text{ °C}$ (if $TOL < -20\text{ °C}$) | <i>COPd or PERd</i> | | – or % |
| For air-to-water heat pumps: Operation limit temperature | <i>TOL</i> | -10 | °C |
| Cycling interval efficiency | <i>COPcyc or PERcyc</i> | | – or % |
| Heating water operating limit temperature | <i>WTOL</i> | 55 | °C |
| Equipped with a supplementary heater: | | | |
| Rated heat output ⁽⁴⁾ | <i>Psup</i> | | kW |
| Type of energy input | | | |
| | | | |
| For air-to-water heat pumps: Rated air flow rate, outdoors | — | | m³/h |
| For water- or brine-to-water heat pumps: Rated brine or water flow rate, outdoor heat exchanger | — | | m³/h |

| | | | |
|---------------------------------|-------------|-----|-----|
| Water heating energy efficiency | η_{wh} | 110 | % |
| Daily fuel consumption | Q_{fuel} | | kWh |
| Annual fuel consumption | <i>AFC</i> | | GJ |

⁽³⁾) For heat pump space heaters and heat pump combination heaters, the rated heat output 'Prated' is equal to the design load for heating 'Pdesignh', and the rated heat output of a supplementary heater 'Psup' is equal to the supplementary capacity for heating 'sup(Tj)'.
⁽⁴⁾ If 'Cdh' is not determined by measurement then the default degradation coefficient is 'Cdh' = 0,9.